


Project Name WALES ME - FORTIN SITE EXPLORATION - LABORATORY TESTING
 Client JONES ASSOCIATES, INC.
 Material Type TEST PIT SAMPLES
 Material Source TP-1

Project Number 22-0013
 Lab ID 28472G
 Date Received 1/5/2022
 Date Completed 1/7/2022
 Tested By PAUL SHAFFER

<u>STANDARD</u> <u>DESIGNATION (mm/μm)</u>	<u>SIEVE SIZE</u>	<u>AMOUNT PASSING (%)</u>	<u>SPECIFICATIONS (%)</u>
150 mm	6"	100	
125 mm	5"	100	
100 mm	4"	100	
75 mm	3"	100	
50 mm	2"	97	
38.1 mm	1-1/2"	90	
25.0 mm	1"	82	
19.0 mm	3/4"	77	
12.5 mm	1/2"	69	
6.3 mm	1/4"	58	
4.75 mm	No. 4	54	
2.00 mm	No. 10	40	
850 μm	No. 20	21	
425 μm	No. 40	12	
250 μm	No. 60	8	
150 μm	No. 100	5	
75 μm	No. 200	2.3	



Comments

